




CPI Limited

**EUROMIX ONE COAT RENDER  
(BBA CERTIFICATE No 03/3997)  
IRISH BUILDING REGULATIONS STATEMENT**



- THIS STATEMENT RELATES TO EUROMIX ONE COAT RENDER AND SETS OUT THE OPINION OF THE BBA ON THE POSITION OF THE PRODUCT UNDER THE BUILDING REGULATIONS IN THE REPUBLIC OF IRELAND.
- It must be read in conjunction with the Front Sheets and relevant Detail Sheets of BBA Certificate No 03/3997.
- It will remain valid provided BBA Certificate No 03/3997 is valid.

### The Building Regulations 1997/2000 Ireland

In the opinion of the BBA, EuroMix One Coat Render, if used in accordance with the provisions of Certificate No 03/3997, will satisfy or contribute to satisfying the relevant requirements.

Requirement:	B2	Internal fire spread (linings)
Comment:		The product meets this Requirement. See sections 11.1 and 11.2 of BBA Certificate No 03/3997.
Requirement:	B4	External fire spread
Comment:		The product meets this Requirement. See sections 11.1 and 11.2 of BBA Certificate No 03/3997.
Requirement:	C4	Resistance to weather and ground moisture
Comment:		Tests and site experience indicate that a wall rendered with the product will meet this Requirement provided installation is in accordance with sections 7.2, 7.3 and 9.1 of BBA Certificate No 03/3997. See also sections 7.1, 9.2, 9.3, and 10 of BBA Certificate No 03/3997.
Requirement:	D1	Materials and workmanship
Comment:		The product is a proper material. See section 14.1 of BBA Certificate No 03/3997.

On behalf of the British Board of Agrément

Date of issue: 14th July 2003

Chief Executive